

Residential Well Test Results (April 2021)

Concentrations are in ng/l (ppt)

Sample ID	PFOA	PFOS	Total PFOA & PFOS
JW0183	ND	ND	ND
JW0174	ND	ND	ND
JW0173	ND	1.7	1.7
JW0172	1.8	3.8	3.8
JW0170	ND	42.4	42.4
JW1210	ND	ND	ND
JW0129	ND	ND	ND
JW0128	ND	0.7	0.7
JW0127	ND	5.8	5.8
JW0122	1.5	62.3	63.8
JW0121	1.1	29.5	30.6
JW0135	1.4	34.5	35.9
JW0134	1.6	68.7	70.3
JW0133	1.2	39.5	40.7
JW0131	1.1	26.5	27.6
JW0130	ND	5.8	5.8
JW1213	ND	8.1	8.1
JW0138	1.5	62.0	63.5
JW0139	1.1	38.2	39.3
JW1310	1.2	34.0	35.2
JW1312	1.7	45.2	46.9
JW1313	1.1	25.4	26.5
JW1315	0.7	12.6	13.3
JW1316	ND	6.2	6.2
JW1215	0.7	31.7	32.4
JW1216	1.3	43.3	44.6
JW1217	1.3	42.7	44.0
JW1218	1.1	34.8	35.9
JW1219	1.2	21.4	22.6
JW1220	0.8	13.2	14.0
JW1222	0.7	11.4	12.1
JW1224	1.2	6.8	8.0

WW-201	ND	23	23
WW-202	ND	14	14
WW-203	ND	17	17
WW-204	ND	ND	ND
WW-205	ND	ND	ND
WW-206	ND	35	35
WW-210	ND	24	24
WW-211	ND	ND	ND
WW-213	ND	17	17
WW-214	ND	16	16
WW-215	2.5	47	49.5
WW-217	2.2	26	28.2
WW-218	ND	ND	ND
WW-219	2.2	26	28.2
UW-1	ND	ND	ND
UW-2	ND	ND	ND
UW-3	ND	ND	ND
WW-1	ND	ND	ND
WW-2	ND	24	24
WW-3	ND	22	22
WW-4	ND	ND	ND
WW-5	ND	8.5	8.5
WW-6	ND	ND	ND
WW-7	ND	ND	ND
WW-9	ND	32	32
WW-10	ND	ND	ND
WW-11	ND	ND	ND
WW-12	ND	ND	ND
WW-13	ND	ND	ND
WW-14	ND	4.6	4.6
WW-3002	ND	ND	ND
WW-3003	ND	ND	ND
WW-3006	ND	ND	ND
WW-3008	ND	ND	ND
WW-3009	ND	ND	ND
WW-3010	ND	ND	ND
WW-3012	ND	ND	ND

WW-3013	ND	ND	ND
WW-3014	ND	ND	ND
WW-3015	ND	ND	ND
WW-3016	ND	ND	ND
WW-3018	ND	ND	ND
WW-3021	ND	ND	ND
WW-3022	ND	4.7	4.7
WW-3024	ND	ND	ND
WW-3027	ND	ND	ND
WW-3031	ND	2.4	2.4
WW-3032	ND	ND	ND
WW-3035	ND	ND	ND
WW-3036	ND	ND	ND
WW-3037	ND	ND	ND
WW-3038	ND	ND	ND
WW-3039	ND	ND	ND
WW-3042	ND	ND	ND
WW-3044	ND	ND	ND
WW-3046	ND	ND	ND
WW-3047	ND	ND	ND
WW-3048	ND	ND	ND
WW-3049	ND	ND	ND
WW-3050	ND	ND	ND
WW-3053	ND	ND	ND
WW-3057	ND	ND	ND
WW-3059	ND	ND	ND
WW-3063	ND	ND	ND
WW-3064	ND	ND	ND
WW-3065	ND	10	10
WW-3066	ND	ND	ND
WW-3077	2.4	15	17.4
WW-3082	ND	ND	ND
WW-3085	ND	ND	ND
WW-3087	ND	ND	ND
WW-3089	ND	ND	ND
WW-3090	ND	ND	ND
WW-3091	ND	ND	ND

WW-3092	ND	ND	ND
WW-3095	ND	ND	ND
WW-3096	ND	ND	ND
WW-3097	ND	ND	ND
WW-3098	ND	ND	ND
WW-3099	ND	ND	ND
WW-3118	ND	ND	ND
WW-3119	ND	4.3	4.3
WW-3120	ND	23	23
WW-3122	ND	ND	ND
WW-3124	ND	ND	ND
WW-3128	ND	ND	ND
WW-3129	ND	ND	ND
WW-3131	ND	ND	ND
WW-3134	ND	ND	ND
WW-3135	ND	ND	ND
WW-3139	2.7	26	28.7
WW-3141	ND	10	10
WW-3143 D	ND	6.8	6.8
WW-3143 S	ND	ND	ND
WW-3149	ND	ND	ND
WW-3150	ND	ND	ND
WW-3151	ND	ND	ND
WW-3152	ND	ND	ND
WW-3153	ND	ND	ND
WW-3154	ND	14	14
WW-3155	ND	ND	ND
WW-3158	ND	16	16
WW-3159	ND	23	23
WW-3160	ND	ND	ND
USEPA LHA	70	70	70

Exceeds USEPA Lifetime Health Advisory of 70 ppt, May 2016

Notes:

ng/L = nanograms per liter, or ppt

PFAS Drinking Water by USEPA Method 537.1

ND = not detected at the reporting limit

UW - Utility district well

JW and WW = Well water

D - deep well; S - shallow well

PFAS = Per and Polyfluorinated Alkyl Substances

PFOA = Perfluorooctanoic acid

PFOS = Perfluorooctane sulfonate